

OFFICE USE ONLY  
 Log No. 48952  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26597

1. OWNER NEVADA JOHNSON ADDRESS AT WELL LOCATION 1024 JOHNSON LN  
 MAILING ADDRESS GARDNERVILLE, NV MINDEN, NV

2. LOCATION SW 1/4 SW 1/4 Sec. 32 T. 14 N. R. 20 E DOUGLAS County  
 PERMIT NO. 21-020-49 JOHNSON LANE Subdivision Name  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MVD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	1	1
Course Sand / Small gravel		1	37	36
Sandy clay / gravel		37	45	8
large gravel / sandy clay		45	80	35
Sandy clay / gravel		80	110	30
gravel / sandy clay	<input checked="" type="checkbox"/>	110	140	30

95 MAY 24 AM 10:42  
 STATE OF NEVADA

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 100 Feet  
10 5/8 Inches 9 7/8 Inches  
 100 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>140</u>

 Perforations:  
 Type perforation FACTORY SLOTTED  
 Size perforation 3 X 3/32  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 140 feet  
 9. WATER LEVEL  
 Static water level 5 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

Date started 5-18 19 95  
 Date completed 5-19 19 95

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>—</u>	<u>1</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD Contractor  
FALLON, NV 89406  
 Nevada contractor's license number 27673  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 5-22-95