

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **26602**

1. OWNER **BIFF PLEMEL** ADDRESS AT WELL LOCATION **1519 WILLOW CREEK**  
 MAILING ADDRESS **GARDNERVILLE, NV** **GARDNERVILLE, NV**

2. LOCATION **NW 1/4 SW 1/4 Sec 35 T 13** **N 20 E** **DOUGLAS** County  
 PERMIT NO. **23-540-08** **WILLOW CREEK** Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other **MUD**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY W/GRAVEL		0	15	15
CEMENTED GRAVEL		15	45	30
SANDY CLAY W/GRAVEL		45	87	42
SANDY CLAY		87	96	9
SAND + GRAVEL		96	122	26
SANDY CLAY		122	126	4
SAND + GRAVEL	✓	126	130	4
CEMENTED GRAVEL		130	147	17
SAND + GRAVEL	✓	147	170	23

8. WELL CONSTRUCTION  
 Depth Drilled **170** Feet Depth Cased **170** Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
**10 5/8** Inches **0** Feet **50** Feet  
**9 7/8** Inches **50** Feet **170** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6 5/8</b>	<b>13</b>	<b>.188</b>	<b>±1</b>	<b>170</b>

Perforations:  
 Type perforation **FACTORY SLOTTED**  
 Size perforation **3 x 3/32**  
 From **150** feet to **170** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **50**  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From **50** feet to **170** feet

9. WATER LEVEL  
 Static water level **45** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature **COLD** °F Quality **GOOD**

Date started **5-18**, 19 **95**  
 Date completed **5-22**, 19 **95**

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<b>AIR</b>	<b>25+</b>	<b>—</b>	<b>1</b>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **EDDCO EXPLORATION, INC** Contractor  
 Address **7780 CURRY RD** Contractor  
**FALLON, NV 89406**  
 Nevada contractor's license number issued by the State Contractor's Board **27673**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1726**  
 Signed **Pat J. Moore**  
 By driller performing actual drilling on site or Contractor  
 Date **5-22-95**