

OFFICE USE ONLY
 Log No. 48768
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28912

1. OWNER DECARLO CONSTRUCTION ADDRESS AT WELL LOCATION 1609 TERRY ANN
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE

2. LOCATION NW 1/4 SW 1/4 Sec. 26 T 14 N S R 20 E DOUGLAS County
 PERMIT NO. 21-240-05 JOHNSON LANE Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>25</u>	<u>25</u>
<u>Sandy clay w/ coarse sand</u>		<u>25</u>	<u>80</u>	<u>55</u>
<u>Sandy clay</u>		<u>80</u>	<u>95</u>	<u>15</u>
<u>Sandy clay w/ coarse sand</u>		<u>95</u>	<u>140</u>	<u>45</u>
<u>Sandy clay</u>		<u>140</u>	<u>170</u>	<u>30</u>
<u>Sandy clay w/ coarse sand</u>		<u>170</u>	<u>197</u>	<u>27</u>
<u>Sandy clay w/ coarse sand</u>	<input checked="" type="checkbox"/>	<u>197</u>	<u>221</u>	<u>24</u>
<u>Sandy clay w/ coarse sand</u>		<u>221</u>	<u>278</u>	<u>57</u>
<u>Sandy clay w/ coarse sand</u>	<input checked="" type="checkbox"/>	<u>278</u>	<u>295</u>	<u>17</u>
<u>Sandy clay</u>		<u>295</u>	<u>300</u>	<u>5</u>

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 50 Feet
9 7/8 Inches 50 Feet 300 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+2</u>	<u>300</u>

Perforations:
 Type perforation Factory slotted / T.C.
 Size perforation 3 X 3/2
 From T.C. 200 feet to 220 feet
 From Factory 250 feet to 300 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 300 feet

9. WATER LEVEL
 Static water level 155 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV 89406
 Nevada contractor's license number 27673
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1535
 Division of Water Resources, the on-site driller
 Signed Jerald W. Dineen
 By driller performing actual drilling on site or contractor
 Date 6-22-95

Date started 6-15 1995
 Date completed 6-22 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>205</u>	<u>---</u>	<u>3</u>