

OFFICE USE ONLY
Log No. 19476
Permit No. _____
Basin. 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28928

1. OWNER LONNIE MASON ADDRESS AT WELL LOCATION 421 HANSEN LN
MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE

2. LOCATION SW 1/4 Sec 35 T 12 N S R 19 E DOUGLAS County

PERMIT NO. 19-070-19 Parcel No. 1218-02-000-001 Subdivision Name FOOTHILL NEW APN

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Grey dk ^{short sticks} sandy clay		3	110	107
Brown dk ^{short sticks} sandy clay	<u>N</u>	110	140	30

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet
HOLE DIAMETER (BIT SIZE)
From 10 5/8 Inches To 0 Feet 140 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>1.88</u>	<u>+3</u>	<u>140</u>

Perforations:
Type perforation Factory slotted / T.C.
Size perforation 3 x 3/32
From T.C. 110 feet to 120 feet
From Factory 120 feet to 140 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 100 Cement Grout
Placement Method: Pumped Concrete Grout
 Poured
Gravel Packed: Yes No
From 100 feet to 140 feet

9. WATER LEVEL
Static water level _____ feet below land surface
Artesian flow 2 G.P.M. _____ P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC Contractor
Address 7780 CURRY RD Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed Jerald W. Plummer
By driller performing actual drilling on site or contractor
Date 11-30-95

Date started 11-24, 1995
Date completed 11-29, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>	<u>—</u>	<u>1 1/2</u>

RECEIVED
 23 DEC 13 AM 11:05
 STATE ENGINEER'S OFFICE