

WHITE-DIVISION OF WATER RESOURCES
 CANARY-CLIENT'S COPY
 PINK-WELL DRILLER'S COPY
 M/D 384305-9
 PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 49752
 Permit No. _____
 Basin 066

NOTICE OF INTENT NO. 15686

1. OWNER SANTA FE PACIFIC GOLD CORP. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 861 W 6th ST.
WINN. NV. 89443
 2. LOCATION SE 1/4 SE 1/4 Sec. 5 T 38 N 42 E Humboldt County
 PERMIT NO. MO 933 Issued by Water Resources Parcel No. 7-131-03 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>ALLUVIUM</u>				
<u>CLAY SAND GRAVEL</u>		<u>0</u>	<u>140</u>	<u>140</u>
<u>SAND PACKED</u>		<u>140</u>	<u>12</u>	<u>128</u>
<u>3/8" BEAD PELLETS</u>		<u>12</u>	<u>10</u>	<u>2</u>
<u>NEAT CEMENT</u>		<u>10</u>	<u>0</u>	<u>10</u>

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 140
6.5 Inches Feet 140 Feet
 _____ Inches Feet _____ Feet
 _____ Inches Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.5</u>	<u>SC 80</u>	<u>P.V.C BLANK</u>	<u>0</u>	<u>40</u>

Perforations:
 Type perforation 2.5" SC 80 P.V.C SCREEN
 Size perforation 0.20
 From 40 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 10' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 12 feet to 140 feet

9. WATER LEVEL
 Static water level 68' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 6-21-95, 1995
 Date completed 6-21-95, 1995

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>100</u>	<u>6</u>		<u>1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ecklund Drilling Co., Inc. Contractor
 Address P.O. Box 2786 Contractor
Eiko, Nevada 89803
 Nevada contractor's license number issued by the State Contractor's Board 0030823
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1788
 Signed John Well
 By driller performing actual drilling on site or contractor
 Date 6-22-95