

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21859

Consultant:

1. OWNER Steffen Robertson and Kirsten ADDRESS AT WELL LOCATION 1250 W. 4th St. Reno, Nv.
 MAILING ADDRESS 1755 East Plumb Lane #241 Western Energetix
Reno, Nevada 89502 419 W. Plumb Lane, Reno, Nv. 89509
 2. LOCATION DAAB 1/4 Sec. 10 T. 19N N/S R. 19 E Washoe County
 PERMIT NO. M/O 665 MW-3 006-223-07 Reno
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Tubex

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--|--------------|------|------|------------|
| Concrete, Road Base (GP) | | 0 | 4" | 4" |
| Sandy Gravel (GP), with silt, boulders. | | 1 | 5 | 4 |
| Silty Clay (CL), stiff, low to medium plasticity, slightly moist, brown. | | 5 | 13 | 8 |
| Sandy Gravel (GP), with boulders, silt, slightly moist, grey-brown. | | 13 | 18 | 5 |
| Sand (SP), with cobbles, boulders, non-plastic, black grey. | | 18 | 29 | 11 |
| Clayey Gravels (GC), with boulders, non-plastic, wet to saturated. | | 29 | 39.5 | 10.5 |

8. WELL CONSTRUCTION
 Depth Drilled 39.5 Feet Depth Cased 39.5 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 5/16 Inches To 0 Feet 39.5 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---------------------|-------------------------|-------------|-----------|
| 4" PVC | Blank | Sch 40 | 0 | 14.5 |
| End Cap & Locking Cap/ Locking Well Protector | | | | |

Perforations:
 Type perforation Factory Sawn Slot
 Size perforation .020
 From 14.5 feet to 39.5 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 10.5 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Bentonite Seal 10.5-12.5
 Gravel Packed: Yes No #3 Silica Sand
 From 12.5 feet to 39.5 feet

9. WATER LEVEL
 Static water level n/a feet below land surface
 Artesian flow n/a G.P.M. n/a P.S.I.
 Water temperature n/a °F Quality n/a

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370 Contractor
Reno, Nevada 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date July 18, 1994

Date started June 21, 1993
 Date completed June 21, 1993

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | | |
| <u>no test</u> | | | |

JUN -5 P 3 02
 STATE ENGINEERS UNIT