

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31939

1. OWNER ST. JAMES VILLAGE ADDRESS AT WELL LOCATION ST. JAMES & JOY LAKE ROAD
 MAILING ADDRESS 11766 WILSHIRE BLVD. SUITE 780 LOS ANGELES, CA. 90025

2. LOCATION NW 1/4 NW 1/4 Sec 14 T 17 N/S R 19 E WASHOE County
 PERMIT NO. 59631 Issued by Water Resources Parcel No. THE WOODS Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND & GRAVEL		0	10	10
SAND & CLAY COBBLES		10	50	40
SAND, SILT W/ CLAY		50	100	50
BLACK ROCK W/ CLAY		100	132	32
COARSE GRAVEL, CLAY		132	140	8
SANDY CLAY, GRAVEL		140	160	20
SAND & GRAVEL		160	172	12
ANDESITE - HARD		172	220	28
CLAY, BLACK ROCK		220	228	8
BROWN CLAY, ROCK		228	232	4
SAND, GRAVEL - FINE		232	260	28
ANDESITE		260	280	20
SAND GRAVEL COBBLES		280	312	32
BROKEN ROCK		312	317	5
SANDY W/ CHIPS		317	325	8
SANDY BROWN CLAY		325	330	5
BROWN CLAY, ROCK		330	340	10
BROKEN VOLCANICS		340	350	10
FINE BLACK CHIPS		350	380	30
BROKEN FRACTURED ROCK		380	400	20
BROKEN ANDESITE		400	415	15
RED ROCK		415	428	13
FRACTURED ROCK		428	435	7
BROKEN ROCK		435	438	3
BLACK CINDER ROCK		438	458	20
SANDY ROCK		458	498	40
ANDESITE		498	521	23
BROWN ANDESITE		521	535	14
BLACK ANDESITE		535	575	40
BROWN CLAY ROCK		575	605	30
Date started <u>11-28-95</u>				19 <u>95</u>
Date completed <u>12-22-95</u>				19 <u>95</u>

8. WELL CONSTRUCTION
 Depth Drilled 596 Feet Depth Cased 590 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 Inches 0 Feet 605 Feet
18 Inches 0 Feet 595 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10"		.250	+ 2	350
10"		.25	490	510

Perforations:
 Type perforation LOUVERED FULL-FLOW
 Size perforation .125
 From 350 feet to 490 feet
 From 510 feet to 590 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 590 feet

9. WATER LEVEL
 Static water level NOT AVAILABLE feet below land surface
 Artesian flow 242' G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name SARGENT IRRIGATION COMPANY Contractor
 Address 9955 N. VIRGINIA ST. RENO, NV. 89506 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0021246
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1593
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date DECEMBER 22, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>400</u>	<u>105</u>	<u>240</u>