WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50377 & 50378
Permit No.
Basin 062

NOTICE OF INTENT NO. 29506

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION NW ¼ SE ¼ Sec. 33 T. 36 (N)S R. 47 E. LANDER County
PERMIT NO. M/O-983 (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ALLUVIAL GRAVEL	TRACE	0	200	200
BROWN ROCK	15 GPM	200	460	260
GRAY ROCK WITH CLAYS	200 GPM	460	740	280
GRAY ROCK	250 GPM	740	1100	360
BROWN ROCK	250 GPM	1100	1460	360
GRAY ROCK	250 GPM	1460	1510	50

Date started OCTOBER 2, 19 95
Date completed OCTOBER 14, 19 95

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 1510 Feet Depth Cased 1500 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14-3/4 Inches		0 Feet	200 Feet
8 Inches		200 Feet	540 Feet
7-7/8 Inches		540 Feet	1510 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	22.36	.250	+3	200
2	1.5	SCH 40	+1	380
2	1.5	SCH 40	+1	1460

Perforations:
Type perforation SLOTTED
Size perforation .040
From 380 feet to 420 feet
From 1460 feet to 1500 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 200
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 370, 1450 feet to 430, 1510 feet

9. WATER LEVEL
Static water level #1 108' #2 980' feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 65 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1809
Signed BENJIE STOFLET Benjie Stoflet
By driller performing actual drilling on site or contractor
Date OCTOBER 26, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627