WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50481
Permit No.
Basin

NOTICE OF INTENT NO. 14353

1. OWNER Mike Leo
MAILING ADDRESS
ADDRESS AT WELL LOCATION 2490 Winchester

2. LOCATION NW ¼ SW ¼ Sec. 29 T 20S N/S R 53 E Nye County
PERMIT NO. (Issued by Water Resources) 40-242-21 (Parcel No.) Calvada unit 5 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3'
Caliche		3	5	2'
Clay		5	15	10'
Caliche		15	17	2'
Clay		17	26	9'
Caliche		26	29	3'
Clay		29	41	12'
Caliche		41	43	2'
Clay		43	53	10'
Caliche	W.B.	53	56	3'
Clay		56	69	13
Caliche	W.B	69	71	2'
Clay		71	80	9'
Caliche	W.B	80	83	3'
Clay		83	100	17'
Caliche	W B	100	103	3'
Clay		103	114	11'
Caliche	W.B	114	116	2'
Clay		116	128	12'
Caliche	W.B	128	132	4'
Clay		132	140	8'

DCNR/DWR Received JAN 5 1996 LAS VEGAS OFFICE

Date started 11-14, 1995
Date completed 11-17, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Sawcut
Size perforation ⅛" x 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140' feet

9. WATER LEVEL
Static water level 53 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Great Basin Drilling
Address (Contractor) PO. Box 4220
Pahrump NV 89041-4220
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 1-3-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627