WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50499
Permit No.
Basin

NOTICE OF INTENT NO. 16934

1. OWNER Serenity Homes
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1500 Huracan St.

2. LOCATION SE ¼ SW ¼ Sec. 29 T. 20 N/S R. 53 E Nye County
PERMIT NO. (Issued by Water Resources) 40-383-20 (Parcel No.) Calvada Unit 5 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	4	4
Calichie		4	6	2
Clay		6	13	7
Calichie		13	15	2
Clay		15	37	22
Calichie		37	46	9
Clay		46	51	5
Calichie	WB	51	54	3
Clay		54	65	11
Calichie	WB	65	68	3
Clay		68	76	8
Calichie	WB	76	78	2
Clay		78	89	11
Calichie	WB	89	94	5
Clay		94	101	7
Calichie	WB	101	103	2
Clay		103	116	13
Calichie	WB	116	119	3
Clay		119	129	10
Calichie	WB	129	132	3
Clay		132	140	8

DCNR/DWR Received JAN 30 1996 LAS VEGAS OFFICE

Date started January 11, 1996
Date completed January 13, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From feet to feet
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 51 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address P.O. Box 1220 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dun (By driller performing actual drilling on site or contractor)
Date 1-15-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627