

OFFICE USE ONLY
 Log No. 50613
 Permit No. 137
 Basin

MW-3

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30768

1. OWNER TETRA TECH, INC. ADDRESS AT WELL LOCATION Owyhee, Nevada
 MAILING ADDRESS 1555 W 2200 S Ste B LDS church
SLC, UT 84119

2. LOCATION NW 1/4 NE 1/4 Sec. 26 T. 47 Q/S R. 52 E. Elko County
 PERMIT NO. M/0 958 Well # 1 Tract of Land
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	3"	3"
Clay & Gravel		3"	12'	11'9"
Weathered volcanic rock some clay		12'	98'	86'
Red brown volcanic rock	X	48'	140'	42'
Placed 3' bentonite chip seal above sand pack				
Pumped bentonite slurry from 13' to 97'				
Placed 3' bentonite chip seal above bentonite slurry				
Cemented 0 - 10				
Set vault flush with asphalt				

8. WELL CONSTRUCTION

Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

From	To
6-1/2 Inches	0 Feet 140 Feet
Inches	Feet Feet
Inches	Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PVC	Sch 40	0	140

Perforations:

Type perforation Mill slot
 Size perforation 0.20
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 10 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 90 feet to 140 feet

9. WATER LEVEL

Static water level 85 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. Contractor
 Address P.O. Box 850 Contractor
Elko, NV 89803
 Nevada contractor's license number issued by the State Contractor's Board 020582
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
 Signed John C. Swir
 By driller performing actual drilling on site or contractor
 Date 9-27-95

Date started September 21, 1995.
 Date completed September 21, 1995.

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Blow test 5		

RECEIVED
 95 OCT -2 PM 3:14
 STATE ENGINEERS OFFICE