

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 30931
 Permit No. 1
 Basin 15051
 NOTICE OF INTENT NO. 15051

1. OWNER LESTER & JUDY GEOHRING ADDRESS AT WELL LOCATION 5610 E. Saddletree Rd.
 MAILING ADDRESS _____

2. LOCATION NW 1/4 SE 1/4 Sec. 16 T. 21 S. N/S R. 54 E NYE County _____
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY DIRT		0	7	7'
CLAY-cobbles		7	23	16'
CALICHE		23	26	3'
CLAY		26	34	8'
CALICHE		34	37	3'
CLAY		37	46	9'
CALICHE		46	48	2'
CLAY		48	59	11'
CALICHE	WB	59	62	3'
CLAY		62	79	17'
CALICHE	WB	79	83	4'
CLAY		83	92	9'
CALICHE	WB	92	95	3'
CLAY		95	107	12'
CALICHE	WB	107	113	6'
CLAY		113	124	11'
CALICHE	WB	124	126	2'
CLAY		126	134	8'
CALICHE	WB	134	138	4'
CLAY		138	140	2'

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation FACTORY SAWCUT
 Size perforation 1 5/8 x 3"

From 120 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet

Date started FEB. 29, 1996
 Date completed MAR. 2, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 59 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING Contractor
 Address P.O. Box 4220 Contractor
Rahman, NV. 89041
 Nevada contractor's license number 30880
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1642
 Division of Water Resources, the on-site driller.
 Signed Thomas D...
 By driller performing actual drilling on site or contractor
 Date 3-15-96