

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 50932
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 15048

1. OWNER Ron Tarven ADDRESS AT WELL LOCATION 3241 Rodeo Ave
 MAILING ADDRESS _____
 2. LOCATION SE 1/4 NW 1/4 Sec. 34 T. 20 S. N/S R. 53 E. Nye County
 PERMIT NO. 40-664-21 Parcel No. Calvada Valley Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3
Caliche		3	6	3
Clay		6	15	9
Caliche		15	17	2
Clay		17	25	8
Caliche		25	28	3
Clay		28	38	10
Caliche		38	42	4
Clay		42	56	14
Caliche	WB	56	58	2
Clay		58	70	12
Caliche	WB	70	73	3
Clay		73	87	14
Caliche	WB	87	90	3
Clay		90	106	16
Caliche	WB	106	108	2
Clay		108	120	12
Caliche	WB	120	122	2
Clay		122	134	12
Caliche	WB	134	140	6

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To 140 Feet
D1/4 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.74</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation factory saw cut
 Size perforation 1/2" x 3"
 From _____ feet to _____ feet
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level: 54 feet below land surface
 Artesian flow _____ G.P.M. _____ L.P.S.I.
 Water temperature _____ °F Quality _____

Date started February 29 1996
 Date completed March 2 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address P.O. Box 4220 Contractor
Pahrump, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Dun
 By driller performing actual drilling on site or contractor
 Date 3-18-96

