WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50936
Permit No.
Basin

NOTICE OF INTENT NO. 15061

1. OWNER DONALD MULFORD
MAILING ADDRESS
ADDRESS AT WELL LOCATION 5892 Saddletree

2. LOCATION NE ¼ SE ¼ Sec. 16 T. 21 S N/S R. 54 E. NYE Co. County
PERMIT NO. (Issued by Water Resources) 43-062-17 (Parcel No.) COTTON WOODS (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY DIRT - COBBLES		0	6	6'
CLAY & COBBLES		6	27	21'
CLAY		27	41	14'
CALICHE		41	43	2'
CLAY		43	56	13'
CALICHE		56	58	2'
CLAY		58	69	11'
CALICHE		69	74	5'
CLAY		74	87	13'
CALICHE	WB	87	89	2'
CLAY		89	102	13'
CALICHE	WB	102	105	3'
CLAY		105	113	8'
LIMESTONE	WB	113	119	6'
CLAY		119	127	8'
CALICHE	WB	127	129	2'
CLAY		129	136	7'
CALICHE	WB	136	139	3'
CLAY		139	140	1'

DCNR-DWR Received MAR 26 1996 LAS VEGAS OFFICE

Date started 3-14, 1996
Date completed 3-16, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1/8" X 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 87 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) GREAT BASIN DRILLING
Address (Contractor) P.O. BOX 4220
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 3-18-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627