

Log No. 50942  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16885

1. OWNER Larry Strickland ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 4270 E. Mary Lou 4270 E. Mary Lou  
Pahrump, NV 89041 Pahrump, NV 89041  
 2. LOCATION SW 1/4 NW 1/4 Sec 17 T 21S N/S R 54 E Nye County \_\_\_\_\_  
 PERMIT NO. 45-181-27 Subdivision Name \_\_\_\_\_  
 Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Stock  Test  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Gravel		0	10	10
Dec Calichia		10	25	15
Brown Clay		25	30	5
Calichia		30	41	11
Brown Clay	x	41	55	14
Calichia	x	55	65	10
Brown Clay	x	65	79	14
Calichia	x	79	85	6
Red Sandy Clay	x	85	98	13
Brown Clay	x	98	120	22
Calichia	x	120	142	22
Brown Clay	x	142	156	14
Grey Clay	x	156	179	23
Brown Clay	x	179	188	9
Red Clay	x	188	200	12

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 0 Feet 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	200

Perforations:  
 Type perforation Torch  
 Size perforation 1/4 x 4  
 From 160 feet to 180 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 50  Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 150 feet to 200 feet

Date started April 4, 1996  
 Date completed April 5, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>NA</u>	<u>1/2</u>

9. WATER LEVEL  
 Static water level 51 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Larry Jenkins Contractor  
 Address P.O. Box 3392 Contractor  
Pahrump, NV 89041  
 Nevada contractor's license number 0035901  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1916  
 Division of Water Resources, the on-site driller  
 Signed Larry Jenkins  
 By driller performing actual drilling on site or contractor  
 Date 4-10-96