WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50968
Permit No.
Basin

NOTICE OF INTENT NO. 16955

1. OWNER Las Vegas Homes
MAILING ADDRESS
ADDRESS AT WELL LOCATION 5544 Saddle tree

2. LOCATION NW ¼ SE ¼ Sec. 16 T. 21S N/S R. 54 E. NYE County
PERMIT NO. (Issued by Water Resources) 43-054-19 (Parcel No.) Cottonwoods (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	5	5'
Caliche		5	7	2'
Clay		7	13	6'
Caliche		13	16	3'
Clay		16	25	9'
Caliche		25	27	2
Clay		27	39	12'
Caliche		39	46	7'
Clay		46	55	9'
Caliche		55	58	3'
Clay		58	66	8'
Caliche		66	69	3'
Clay		69	78	9'
Caliche	W.B.	78	81	3'
CLAY		81	97	16'
CALICHE	WB.	97	99	2'
CLAY		99	113	14'
CALICHE	W.B.	113	117	4'
Clay		117	124	7'
Caliche	WB	124	126	2'
CLAY		126	135	9'
Caliche	WB.	135	138	3
CLAY		138	140	2'

Received MAR 5 1996 LAS VEGAS OFFICE

Date started 1-30, 1996
Date completed 2-1, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Sawcut.
Size perforation 1/8" x 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 68 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address P.O. box 4220 (Contractor)
Pahrump NV 89041-4220
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 2-22-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627