WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51122
Permit No. 55243
Basin 212

NOTICE OF INTENT NO. 0856

1. OWNER Feista Homes
MAILING ADDRESS 4275 S. Bell Dr.
Las Vegas, NV. 89118

ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ SW ¼ Sec. 29 T 22S N/S R 61 E Clark County
PERMIT NO. 55243 (Issued by Water Resources) 177-29-301-012 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| gravel-loose to | | | | |
| cemented | | 0 | 105 | |
| rock & gravel w/ | | | | |
| clay steaks | | 105 | 220 | |
| rock & clay | | 220 | 355 | |

RECEIVED
NOV 17 1995
DCNR/DWR
LAS VEGAS OFFICE

Date started 11-2, 19 95
Date completed 11-6, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 355 Feet Depth Cased 357 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 9 7/8 | 0 | 355 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 14.2 | .188 | +2 | 355 |
| | | | | |

Perforations:
Type perforation machine
Size perforation 1/8 X 2½"
From 235 feet to 255 feet
From 315 feet to 335 feet
From ... feet to ... feet
From ... feet to ... feet
From ... feet to ... feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 355 feet

9. WATER LEVEL
Static water level 157 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Briner Drilling Inc. (Contractor)
Address 555 N. Parkson Rd. (Contractor)
Henderson, NV. 89015
Nevada contractor's license number issued by the State Contractor's Board 6294A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1338
Signed November 9, 1995
By driller performing actual drilling on site or contractor
Date M. W. Bim

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627