WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 51133
Permit No.
Basin 212

NOTICE OF INTENT NO. (UNK.)

1. OWNER Dames & Moore
MAILING ADDRESS 6 Hutton Center Dr., Ste. 700, Santa Ana, CA 92707
ADDRESS AT WELL LOCATION 3115 E. Fremont St., Las Vegas, NV

2. LOCATION NW ¼ SE ¼ Sec. 1 T. 21 N/S R. 61 E. Clark County
PERMIT NO. MO-2594 (Issued by Water Resources) (unk) Parcel No. (unk) Subdivision Name

3. WORK PERFORMED DM-J
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE N/A
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Asphalt | | 0 | 0.5 | 0.5 |
| Si Sand to Silt | | 0.5 | 23 | 22.5 |

Date started March 13, 1996
Date completed March 13, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| N/A | | |

8. WELL CONSTRUCTION
Depth Drilled 23 Feet Depth Cased 21 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 9 Inches | 0 Feet | 23 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2" | 0.93 | Sch 40 | 0.5 | 21 |

Perforations:
Type perforation Slotted
Size perforation .020
From 6.3 feet to 20.7 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 3.7'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 3.7 feet to 23 feet

9. WATER LEVEL
Static water level 11' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled ~~under my supervision~~ by West HazMat and the report is true to the best of my knowledge.
Name Weber Environmental (Contractor)
Address 115 S. Weber Dr., Ste. 1, Chandler, Az 85226 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0039528
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1910
Signed James M. Yurlovich (By driller performing actual drilling on site or contractor)
Date 4-16-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627