WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 61414 in book
Permit No.
Basin 163

NOTICE OF INTENT NO. 16482

1. OWNER PHIL - MACIEJEWSKI
MAILING ADDRESS
ADDRESS AT WELL LOCATION PAWNEE + LEAD SANDY VALLEY

2. LOCATION SE¼/NW¼ SE¼/NE¼ Sec. 26 T. 24 N/S R. 56 E. CLARK County
PERMIT NO. Issued by Water Resources | Parcel No. 580-240-085 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	6	6
CALICHIE		6	11	5
CLAY		11	22	11
CALICHIE		22	27	5
CLAY		27	40	13
CALICHIE		40	43	3
CLAY		43	58	15
CALICHIE	Tr	58	62	4
CLAY		62	72	10
CALICHIE	W.B.	72	78	6
CLAY		78	91	13
CALICHIE	W.B	91	96	5
CLAY		96	110	14
CALICHIE	W.B	110	115	5
CLAY		115	123	8
CALICHIE	W.B	123	128	5
CLAY		128	133	5
CALICHIE	WB	133	140	7

RECEIVED MAY 7 1996 LAS VEGAS OFFICE

Date started 4-15, 1996
Date completed 4-20, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 8 INCH BY 3 INCH
From 140 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 140 feet to 50 feet

9. WATER LEVEL
Static water level 515 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BUDGET DRILLING Contractor
Address P.O. BOX 3505 Contractor
PAHRUMP NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 40020
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed By driller performing actual drilling on site or contractor
Date 4-20-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627