

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Winnemucca Farms Inc. ADDRESS AT WELL LOCATION Feedlot Rd. 1 Mile North
MAILING ADDRESS P.O. Box 2130
Nevada 89446 Winnemucca
2. LOCATION SW 1/4 SW 1/4 Sec 24 T 38 S R 38 E County _____
PERMIT NO. 36319 618617 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other Reverse

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil	no	0'	6'	6
Hard Pan		6'	8'	2
Coarse Sand		8'	30'	22
Hard Brown clay Sandstone		30'	41'	11
Med Sand 1/8 fine clay		41'	106'	65
Fine to Coarse Sand.	yes	106'	214'	108
Bra Clay	No	214'	216'	2
Fine to Coarse Sand.	yes	216'	288'	72
Bra Clay Sandstone Mix	No	288'	340'	52
Fine to Coarse Sand.	yes	340'	389'	47
Fine to Coarse with clay	No	389'	400'	13
Fine to Coarse Sand	yes	400'	435'	35
Bra Clay Sandstone	No	435'	450'	15
Fine to Coarse Sand.	yes	450'	460'	10
Bra Clay Streaks Sand.	No	460'	504'	44
Fine to Coarse Sand.	yes	504'	540'	36
Bra Clay Streaks Sand	No	540'	598'	58
Fine to Coarse Sand	yes	598'	623'	25
Bra Clay Sandstone	No	623'	635'	12

8. WELL CONSTRUCTION
Depth Drilled 635' Feet Depth Cased 635' Feet
HOLE DIAMETER (BIT SIZE)
From 28" Inches To 0' Feet 635' Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
18"	70.5	.375	200'	290'
18"	70.5	.375	290'	340'
18"	"	"	380'	390'

Perforations:
Type perforation Wire wrap Johnson
Size perforation 1.040518" Dia.
From 200' feet to 290' feet
From 340' feet to 380' feet
From 390' feet to 430' feet
From 450' feet to 460' feet
From 505' feet to 535' feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50' feet to 635' feet

9. WATER LEVEL
Static water level 169' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature 62 °F Quality Good

Date started April 19, 1996
Date completed April 26, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>2000</u>	<u>80'</u>	<u>2 hrs</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Riverside Inc. Contractor
Address P.O. Box 920 Parma Id. Contractor
83660
Nevada contractor's license number issued by the State Contractor's Board. 0030338
Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 1919
Signed Jerry Daugherty
By driller performing actual drilling on site or contractor
Date 5/19/96

