WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 52018
Permit No.
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9785

1. OWNER Max K Barton
MAILING ADDRESS 2960 Reno ct
Las Vegas Nevada 89117
ADDRESS AT WELL LOCATION 3337 So. Industrial Rd
Las Vegas Nevada

2. LOCATION SE ¼ SE ¼ Sec. 17 T. 21 N/S R. 61 E. Clark County
PERMIT NO. M02720 Issued by Water Resources
162-17-504-001 Parcel No.
Subdivision Name

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☐ Irrigation ☐ Test ☒ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☐ Other ☒ Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Gravel		0	12	
Caliche		12	24	
Clay		24	32	

Date started 5 13, 1996
Date completed 5 16, 1996

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	N/A		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 32 feet
inches
inches
Casing record Sch 40 PVC
Weight per foot Thickness

Diameter	From	To
2 inches	0 feet	30 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Neat Cement
Depth of seal 8 Ft feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 7 feet to 30 feet

Perforations:
Type perforation ~~[illegible]~~ Slot
Size perforation .020
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 18 feet below land surface
Flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Greg Ogle (Contractor)
Address 3611 W. Tompkins (Contractor)
Nevada contractor's license number issued by the State Contractor's Board
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1761
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 5 16 96

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 11-85) (O)-627

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No 52018
Permit No.
Basin 212

NOTICE OF INTENT NO. 9785

1. OWNER Max R Barton
MAILING ADDRESS 2960 Reiger CT
Las Vegas Nevada 89119

ADDRESS AT WELL LOCATION 3337 So. Industrial RD
Las Vegas Nevada

2. LOCATION SE ¼ SE ¼ Sec. 14 T. 21 N/S R. 61 E. Clark County

PERMIT NO M02220 (Issued by Water Resources) | 162-17-504-001 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Gravel		0	11	
Caliche		11	22	
Clay		22	28	

DCNR/DWR MAY 17 1996 LAS VEGAS OFFICE

Date started 5-13, 1996
Date completed 5-16, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 0 Feet Depth Cased 28 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
Sch 40 PVC 2			0	25

Perforations:
Type perforation ~~.020~~ slot
Size perforation .020
From 15 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 12
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 13 feet to 25 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name (Contractor)
Address (Contractor)

Nevada contractor's license number issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1261

Signed (By driller performing actual drilling on site or contractor)
Date 5/16/96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627