

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32604
 ADDRESS AT WELL LOCATION 2578 Snyder Ave Carson City NV 89701

1. OWNER Monir & Naila Eluataki
 MAILING ADDRESS 2578 Snyder Carson City NV 89702
 2. LOCATION SE 1/4 SW 1/4 Sec. 3 T. 14 N S R. 20 E Carson County
 PERMIT NO. 10-491-06
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Rusty Decomposed Granite</u>		<u>0</u>	<u>35</u>	<u>35</u>
<u>Coarse Granite</u>		<u>35</u>	<u>74</u>	<u>39</u>
<u>Black Color Orange Rusty Granite</u>		<u>74</u>	<u>95</u>	<u>21</u>
<u>Hard Broken Granite</u>		<u>95</u>	<u>145</u>	<u>50</u>
<u>Coarse Granite (Little Water)</u>	<u>x</u>	<u>145</u>	<u>152</u>	<u>7</u>
<u>Broken Fractures w/ Rusty Granite</u>	<u>xxx</u>	<u>152</u>	<u>176</u>	<u>24</u>

8. WELL CONSTRUCTION
 Depth Drilled 176 Feet Depth Cased 176 Feet
 HOLE DIAMETER (BIT SIZE)
 From 1 1/4 Inches To 176 Feet
 Inches Feet Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>176</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3 x 3/32
 From 156 feet to 176 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 100 Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 176 feet

9. WATER LEVEL
 Static water level 105 feet below land surface
 Artesian flow _____ G.P.M. 20 P.S.I.
 Water temperature Cold °F Quality Good

Date started 1-3, 1996
 Date completed 1-5, 1996

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>80</u>	<u>30</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A & H Pump Company Contractor
 Address 5551 Hwy 50 E #3 Carson City NV 89701 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael J. Beck
 By driller performing actual drilling on site or contractor
 Date 1-5-96