

OFFICE USE ONLY
 Log No. 52050
 Permit No. 082R
 Basin 082R

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27260

1. OWNER RICK LaMAY ADDRESS AT WELL LOCATION 108 Heindel Road
 MAILING ADDRESS 2444 Sagittarius Drive Reno, Nevada 89506
 2. LOCATION NE 1/4 NW 1/4 Sec. 16 T 20N N/S R 19 E Washoe County
 PERMIT NO. 082-660-09 Black Springs Area
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay, some gravels		1	17	16
Gravel and sand		17	23	6
Brown sandy clay, some gravel		23	41	18
Brown clay		41	127	86
Soft zone (NO WATER)		127	130	3
Brown clay with gravels		130	140	10
Soft zone (NO WATER)		140	145	5
Brown clay with gravels		145	290	145
Soft zone (app 1 GPM)	X	290	294	4
Green volcanic rock		294	320	26
Blue green volcanic rock		320	331	11
Soft zone	X	331	335	4
Blue green volcanic rock		335	375	40

8. WELL CONSTRUCTION
 Depth Drilled 372 Feet Depth Cased 372 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 375 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	375

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 315 feet to 365 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50 foot
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 372 feet

9. WATER LEVEL
 Static water level 151 feet below land surface
 Artesian flow _____ G.P.M. 10 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date January 15, 1996

Date started 1-9-96, 19____
 Date completed 1-10-96, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>10</u>		



Meeting your future with energy

6100 Neil Road, P.O. Box 10100, Reno, Nevada 89520-0400 • 702.689.4011

December 27, 1995

Washoe County Health Department
1001 E. Ninth Street
Reno, NV 89520

RE: Water Service to APN 82-660-09

To Whom It May Concern;

Please be advised, the referenced subject parcel is not in Westpac Utilities water service territory. Because of annexation with the Public Service Commission, the location of Westpac's closest services and the cost of construction, the owners have elected not to request water service from Westpac.

Sincerely,

Ken Briscoe
Sr. Water Resource Technician
Customer Services Engineering

30 MAR 1996 10 11 AM
42-3112-1100P DE
CIVIL SERVICE