WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 52052
Permit No.
Basin 105

NOTICE OF INTENT NO. 28924

1. OWNER RICK EATON CONSTRUCTION
MAILING ADDRESS GARDNERVILLE, NV
ADDRESS AT WELL LOCATION 1736 SOUTH SEE GARDNERVILLE

2. LOCATION SW ¼ SE ¼ Sec. 35 T. 13 N/S R. 20 E. DOUGLAS County
PERMIT NO. — Issued by Water Resources
23-560-07 Parcel No.
WILDFLOWER Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY-GRAVEL/COBBS		0	10	10
GRAVEL/COBBLES		10	30	20
SANDY CLAY		30	53	23
SANDY CLAY/GRAVEL		53	58	5
SAND-GRAVEL		58	76	18
SANDY CLAY		76	91	15
SAND-GRAVEL		91	102	11
SANDY CLAY/GRAVEL		102	134	32
SANDY CLAY		134	175	41
CLAY		175	194	19
SAND/GRAVEL	✓	194	229	35
CLAY		229	234	5
SAND-GRAVEL	✓	234	240	6

Date started 12-22, 19 95
Date completed 12-30, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	25+	—	1/2

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 7/8	Inches	0	Feet	50	Feet
9 7/8	Inches	50	Feet	240	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	240

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 3 X 3/32
From 220 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC (Contractor)
Address 7780 CURRY RD (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1997
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 12-28-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627