

OFFICE USE ONLY
 Log No. 52024
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28930

1. OWNER MR + MRS SPENCE/HERZMAN ADDRESS AT WELL LOCATION 1826 BASELINE
 MAILING ADDRESS MINDEN, NV MINDEN, NV

2. LOCATION SW 1/4 SW 1/4 Sec. 12 T 13 N R 20 E DOUGLAS County
 PERMIT NO. 56288 + 56290 23-400-06 EAST VALLEY
 Issued by Water Resources Parcel No. Subdivision Name

60228, 60227, 60228

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY w/GRAVEL		0	42	42
GRAVEL		42	54	12
SANDY CLAY		54	68	14
GRAVEL		68	98	30
SANDY CLAY w/GRAVEL		98	114	16
GRAVEL	✓	114	132	18
SANDY CLAY w/GRAVEL		132	140	8
SAND + GRAVEL	✓	140	172	32
SANDY CLAY		172	236	64
SAND	✓	236	244	8
SANDY CLAY w/GRAVEL		244	286	42
GRAVEL	✓	286	320	34
SANDY CLAY w/GRAVEL		320	328	8
GRAVEL	✓	328	337	9
SANDY CLAY w/GRAVEL		337	342	5
GRAVEL	✓	342	368	26
SANDY CLAY w/GRAVEL		368	372	4
GRAVEL	✓	372	382	10
SANDY CLAY		382	394	12
GRAVEL	✓	394	400	6

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)
 From 15 Inches To 0 Feet 400 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/8</u>	<u>15</u>	<u>.198</u>	<u>+1</u>	<u>400</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 1/8
 From 130 feet to 170 feet
 From 240 feet to 245 feet
 From 285 feet to 400 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 400 feet

9. WATER LEVEL
 Static water level 150 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 1/11 1996
 Date completed 2/15 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>100 +</u>	<u>-</u>	<u>8</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD Contractor
FALLON, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 2-15-96

