

OFFICE USE ONLY  
 Log No. 52061  
 Permit No. \_\_\_\_\_  
 Basin 203



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 1410


1. OWNER Roseleen Anderson ADDRESS AT WELL LOCATION 7 miles north of Caliente US 93 west side  
 MAILING ADDRESS 22320 Echo Lake Road Sackemish, Washington 93290  
 2. LOCATION 3/4 N/W 1/4 N/W 1/4 Sec 2 T 3 N 67 E Lincoln County  
 PERMIT NO. 0 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	4	4
Sand-boulders		4	90	86
Cemented Gravel		90	160	70
Clay		160	185	15
Clay-Gravel	X	185	205	35
Clay		205	210	5

T.D. 210



8. WELL CONSTRUCTION  
 Depth Drilled 210 Feet Depth Cased 210 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 210 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	-	<u>.188</u>	<u>0</u>	<u>210</u>

 Perforations:  
 Type perforation factory  
 Size perforation 1 1/2" x 3"  
 From 170 feet to 210 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 210 feet

9. WATER LEVEL  
 Static water level 162 feet below land surface  
 Artesian flow 0 G.P.M. 0 P.S.I.  
 Water temperature cold °F Quality Good

Date started 4-22-96, 19\_\_\_\_  
 Date completed 4-28-96, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailer	<u>14</u>	<u>10</u>	<u>5</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Davis Drilling Contractor  
 Address P.O. Box 54  
Hiko Nev. 89017  
 Nevada contractor's license number issued by the State Contractor's Board 0028266  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1194  
 Signed Mike Davis  
 By driller performing actual drilling on site or contractor  
 Date 4-28-96