

OFFICE USE ONLY
 Log No. 52068
 Permit No. 1
 Basin 1

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28885
3 miles South of Ely

1. OWNER Gary Sprouse ADDRESS AT WELL LOCATION 3 miles South of Ely
 MAILING ADDRESS HC 66 Box 56A
Neola, Utah 84053

2. LOCATION NE 1/4 NE 1/4 Sec. 35 T. 16 N/S.R. 63 E. White Pine County
 PERMIT NO. WELL No 4 2A Parcel Map No. 111
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel		0	25	25
Clay & Gravel		25	100	75
Clay		100	105	5
Gravel		105	110	5
Clay & Gravel		110	130	20
Clay		130	210	80
Clay & Gravel		210	235	25
Clay		235	275	40
Sand & Gravel with Clay Seams	x	275	310	35
Clay		310	335	25
Sand & Gravel with Clay Seams	x	335	402	67

8. WELL CONSTRUCTION
 Depth Drilled 402 Feet Depth Cased 402 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 402 Feet
 From 0 Feet To 402 Feet
 From 0 Feet To 402 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	402

Perforations:
 Type perforation Factory
 Size perforation 1/8" x 2 1/2" 6 rows
 From 302 feet to 402 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 402 feet

9. WATER LEVEL
 Static water level 277 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started January 15, 19 96
 Date completed January 22, 19 96

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	35	103	1 1/2

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Avenue Contractor
Ely, NV 89301
 Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641
 Signed Jerrold D. Christiansen
 By driller performing actual drilling on site or contractor
 Date February 5, 1996