


PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32726



1. OWNER Globe TURBOCHARGER ADDRESS AT WELL LOCATION 201 EDISON  
MAILING ADDRESS 201 EDISON RENO NV RENO NV  
2. LOCATION SE 1/4 NE 1/4 Sec 17 T 19 N R 30 E WASHOE County  
PERMIT NO. MO 1043 Issued by Water Resources Parcel No. 12/318/17 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other 1.5A

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>ASPHALT</u>		<u>0</u>	<u>2"</u>	
<u>FILL</u>		<u>2"</u>	<u>1.5</u>	
<u>Lt. yellow brown silty SAND</u>		<u>1.5</u>	<u>7</u>	
<u>DARK BROWN CLAYEY FINE SAND</u>		<u>7</u>	<u>11.5</u>	
<u>TOPSOIL</u>				
<u>Lt. Brown clayey gravel</u>		<u>11.5</u>	<u>15</u>	
<u>DENSE moist gravels + COBBLES 2" dia.</u>		<u>15'</u>	<u>17'</u>	
<u>GREY SANDY gravels w/ few fines</u>				
<u>SAND</u>				

8. WELL CONSTRUCTION  
Depth Drilled 17 Feet Depth Cased 17 Feet  
HOLE DIAMETER (BIT SIZE)  
From 10 Inches To 17 Feet  
Inches Feet  
Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>		<u>SAH 80</u>	<u>0</u>	<u>7</u>

Perforations:  
Type perforation SLOT  
Size perforation .010  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From 7 feet to 17 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Surface Seal:  Yes  No Seal Type:  Neat Cement  
Depth of Seal 5  Cement Grout  
Placement Method:  Pumped  Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 5 feet to 17 feet

Date started 5.15 1996  
Date completed 5.15 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
Static water level 7.55 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name NEVADA Drilling Inc Contractor  
Address 75 Lewers Creek RD Contractor  
CARSON CITY NV 89704  
Nevada contractor's license number 13697A issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1902  
Signed John B. Leisch  
By driller performing actual drilling on site or contractor  
Date 5.24.96