WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 52074
Permit No.
Basin 05

NOTICE OF INTENT NO. 28931

1. OWNER GENOA COMPANY
MAILING ADDRESS GENOA, NV
ADDRESS AT WELL LOCATION 1220 QUAIL RIDGE MINDEN, NV

2. LOCATION SE ¼ SE ¼ Sec. 4 T. 12 N R. 19 E DOUGLAS County
PERMIT NO. — (Issued by Water Resources) 19-051-32 (Parcel No.) AUTUMN HILLS (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders & DG		0	83	83
DG		83	122	41
Granite w/Fractures		122	252	130
DG w/sandy clay	✓	252	261	9
Granite w/fracts		261	267	6
Sandy clay w/DG		267	278	11
Fractured Granite	✓	278	284	6
Granite some Fracts		284	317	33
DG w/sand some clay	✓✓	317	380	63

Date started 12-1, 1995
Date completed 1-2, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	10+	—	4

8. WELL CONSTRUCTION
Depth Drilled 380 Feet Depth Cased 380 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	50 Feet
9 7/8 Inches	50 Feet	310 Feet
5 3/4 Inches	310 Feet	380 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+2	310
5	10	.188	300	380

Perforations:
Type perforation Factory Slotted / T.C.
Size perforation 3 X 3/32
From TC 250 feet to ~~290~~ 290 feet
From Factory 290 feet to 310 feet
From TC 300 feet to ~~380~~ 260 feet
From Factory 260 feet to 380 feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 380 feet

9. WATER LEVEL
Static water level 220 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC (Contractor)
Address 7780 CURRY RD (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed Gerald W. Phinnell (By driller performing actual drilling on site or contractor)
Date 1-3-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627