WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 22075
Permit No.
Basin 08

NOTICE OF INTENT NO. 28122

1. OWNER Fred Aldridge & Terry Budkowski
MAILING ADDRESS 34 Rio Vista Yerington NV. 89447
ADDRESS AT WELL LOCATION 34 Rio Vista Yerington NV. 89447

2. LOCATION SW ¼ SW ¼ Sec. 22 T. 13 ☒S R. 25 E. Lyon County
PERMIT NO. 54473 Issued by Water Resources | 12-041-19 / 12-041-20 Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☑ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
overburden		0	3	3
Brown Clay		3	18	15
Course Sands & Gravels Gray Clay Seems		18	63	
Brown & Gray Clay		63	87	
Course Fine Sands Gravels		87	105	
Large Gravels Pole Gravels	xxx	105	176	

Date started 2-16, 1996
Date completed 2-19, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
400-500	30	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 176 Feet Depth Cased 176 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
17¼ Inches		0 Feet	176 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10	21.02	.250	0	176

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 105 feet to 176 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 105
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 105 feet to 176 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow G.P.M. 400-500 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co. (Contractor)
Address 5551 Hwy 50 E #3 Carson City NV. 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack (By driller performing actual drilling on site or contractor)
Date 2-19-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627