

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28144

1. OWNER UNR ADDRESS AT WELL LOCATION 1412 S MT. LOAST ST. RENO NV. #28
 MAILING ADDRESS _____ (STEAR, NV)
 2. LOCATION NE 1/4 SW 1/4 Sec. 29 T. 21 N. R. 19 E. WASHOG County
 PERMIT NO. MO955-A Issued by Water Resources Parcel No. _____ Subdivision Name SOIL BIO-VENT WELLS

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic SBW Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0"	6"	
BROWN CLAYEY MED. SANDS		6"	7'	
<u>CEMENTED</u> Reddish BROWN silty FINE SANDS		7'	10'	
BROWN SANDY CLAY		10'	16'	
Grey poorly GRADED MED. SAND		16'	21'	
BROWN SANDY CLAY		21'	24'	
BROWN CLAYEY SANDS		24'	38'	

8. WELL CONSTRUCTION 1028' @ 38'
 Depth Drilled 38 Feet Depth Cased 1028' @ 38' Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 38 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>		<u>SCH 80</u>	<u>0</u>	<u>8</u>
<u>1.32</u>		<u>SCH 80</u>	<u>0</u>	<u>36.5</u>
<u>1.32</u>		<u>SCH 80</u>	<u>0</u>	<u>36</u>

Perforations:
 Type perforation SLOT / ceramic
 Size perforation drill size #2
 #1 From 8 feet to 28 feet 4" ID
 #2 From _____ feet to _____ feet
 #3 From 36.5 feet to 38 feet ceramic
 #3 From 36 feet to 38 feet 2" ID

Surface Seal: Yes No Seal Type Neat Cement
 Depth of Seal 6
 Placement Method: Pumped Poured PELL plug
 Cement Grout Concrete Grout
 Gravel Packed: Yes No Bentonite pellets @ 30 to 34
 From 6 feet to 30 feet 38 feet

Date started 4-18 1996
 Date completed 4-18 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 26 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA Drilling INC. Contractor
 Address 75 Lewers Creek Rd Contractor
Carson City NV 89704
 Nevada contractor's license number 13697A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1902
 Division of Water Resources, the on-site driller
 Signed John Schiel
 By driller performing actual drilling on site or contractor
 Date 6-11-96