ABANDONMENT # 48

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 52113
Permit No.
Basin

NOTICE OF INTENT NO. 304

1. OWNER Cortez Gold Company
MAILING ADDRESS STAR RT HC-66-5C
Beowawe 89821

ADDRESS AT WELL LOCATION Same

2. LOCATION SW ¼ SW ¼ Sec. 7 T. 27 N/S R. 48 E. Eureka County
PERMIT NO. M/O-207 (Issued by Water Resources) | N/A (Parcel No.) | N/A Hole # TB-15 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Tripped in hole pump Cement From 45.4 ft to Surface Trip out Glue 2" male Thread adaptor onto end of pipe and pump Cement into hole under pressure Trip in to hole when hole quits Accepting Fluid Knock Cap off the end of the 2" PVC pipe and Rip Casing From 45.4 to Surface then Represource pipe				
Pumped 15 Sacs of Portland Type II Cement Slurry into hole				

Date started 5-23, 1996
Date completed 5-23, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 46.5 Feet Depth Cased 45.4 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6.5 Inches	0 Feet	46.5 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC Sch 80		+2	45.4

Perforations:
Type perforation Hacksaw Cut Every 0.5 ft
Size perforation
From 28.4 feet to 44.9 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 76'
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 25.2 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson (Contractor)
Address 10760 Grass Valley Rd (Contractor)
Winn, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 01375
Signed (By driller performing actual drilling on site or contractor)
Date 5-24-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627