

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY


STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 52121

Permit No. _____

Basin _____



WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28584

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

1. OWNER PLACER DOME TECHNICAL SERVICES ADDRESS AT WELL LOCATION _____
MAILING ADDRESS HC66-50 STAR ROUTE CORTEZ MINE
BEOWAWE, NV 89821

2. LOCATION NW 1/4 SW 1/4 Sec 32 T 28 N S R 47 E LANDER County
PERMIT NO. 57139 Parcel No. N/A Subdivision Name N/A
Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other FLOODED REV

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ALUVIUM		0	410	410
GREY SILTSTONE		410	420	10
TAN SILTSTONE		460	580	120
GREY SILTSTONE		580	600	20
TAN SILTSTONE		600	670	70
GREY SILTSTONE		670	690	20
GREY SILTSTONE W/ VOLCANICS		690	735	45

8. WELL CONSTRUCTION
Depth Drilled 735 Feet Depth Cased 730 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>38"</u> Inches	<u>0</u> Feet <u>20</u> Feet
<u>31</u> Inches	<u>20</u> Feet <u>320</u> Feet
<u>24</u> Inches	<u>320</u> Feet <u>730</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>32</u>	<u>126</u>	<u>3/8</u>	<u>0</u>	<u>20</u>
<u>26</u>	<u>102</u>	<u>3/8</u>	<u>0</u>	<u>320</u>
<u>18</u>	<u>71</u>	<u>3/8</u>	<u>+3</u>	<u>480</u>

Perforations:
Type perforation WIRE WRAP
Size perforation .08
From 480 feet to 720 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 320 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 10 feet to 730 feet

9. WATER LEVEL
Static water level 255.2 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 98 °F Quality N/A

Date started MAY 25 19 96
Date completed JUNE 2 19 96

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>385</u>	<u>8</u>	<u>1 HOUR</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING Contractor
Address 2286 WEST 1500 SOUTH Contractor
SALT LAKE CITY, UT 84104
Nevada contractor's license number 0021976 issued by the State Contractor's Board.
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2000
Signed BILL EDDY *Bill Eddy*
By driller performing actual drilling on site or contractor
Date 6-2-96