WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 52203
Permit No.
Basin 212

NOTICE OF INTENT NO. 10932

1. OWNER Las Vegas Paving
MAILING ADDRESS 4920 S. Decator
Las Vegas NV 89103

ADDRESS AT WELL LOCATION Harmon St
Between McLeod + Topaz

2. LOCATION ___ ¼ ___ ¼ Sec. 23-24 T 21 N/S R 61 E ___ County
PERMIT NO. DW-1024 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other Temp

4. PROPOSED USE Dewater
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other Bucket

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill Sand		0	2	2
Silty Clays		2	11	9
Caliche		11	12	1
Silty Sands + Clays		12	28	16
Silty Clays		28	35	7
Clays		35	40	5

RECEIVED
MAR 23 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 3-9, 1995
Date completed 3-9, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
24 Inches	0 Feet	40 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8		Sch 40	0	40

Perforations:
Type perforation Saw Cut
Size perforation 1030
From 20 feet to 40 feet
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet

Surface Seal: ☐ Yes ☑ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 0 feet to 40 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Griffin Contract Dewatering (Contractor)
Address 536 E. Maitland (Contractor)
Ontario CA 91764
Nevada contractor's license number issued by the State Contractor's Board 0031246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1968T
Signed ___ (By driller performing actual drilling on site or contractor)
Date 3-9-95

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-6