



WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 0377

PRINT OR TYPE ONLY

1. OWNER Antonio Hernandez ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____

2. LOCATION SE 1/4 NW 1/4 Sec. 15 T. 16 N/S R. 48 E Nye County

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand & Gravel</u>		<u>0</u>	<u>120</u>	<u>120</u>
<u>Gray Clay</u>		<u>120</u>	<u>135</u>	<u>15</u>
<u>Sand & Fine Gravel</u>		<u>135</u>	<u>156</u>	<u>21</u>
<u>Note</u>				
<u>Stuck 978</u>				
<u>Osg. 126</u>				
<u>Install 6" casing</u>				
<u>From 116 to 126</u>				
<u>Note</u>				
<u>Lost Circ. 60'</u>				
<u>Cemented from 60' to 20'</u>				

RECEIVED
 JUL 30 1984
 Div. of Water Resources
 Branch Office - Las Vegas, Nev.

8. WELL CONSTRUCTION

Diameter hole 12 1/4 inches Total depth 156 feet
 Casing record 126' 9 5/8 40' 6 7/8
 Weight per foot _____ Thickness _____
 Diameter From To
9 5/8 inches 0 feet 126 feet
6 7/8 inches 116 feet 156 feet
 _____ inches _____ feet _____ feet
 _____ inches _____ feet _____ feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type Cement
 Depth of seal 60 feet
 Gravel packed: Yes No
 Gravel packed from 60 feet to 156 feet
 Perforations:
 Type perforation Arch
 Size perforation 1/8" x 1/2" 3 Rows
 From 76 feet to 76 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 110 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Custom Drilling Inc Contractor
 Address 4425 Stacey Ave L.U. Contractor
 Nevada contractor's license number 19219
 Nevada contractor's drillers number _____
 Nevada driller's license number 1081 Actual Driller
 Signed C.R. Cafarella Contractor
 Date 5-30-84

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours