WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

in Book

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 52316
Permit No.
Basin 200

1. OWNER Johanna M. Adams JOAN ADAMS ADDRESS P.O. Box 12394 Las Vegas, Nevada 89112

2. LOCATION NE ¼ SE ¼ SE ¼ Sec. 26 T. 16 S R. 49 E. Nye County
PERMIT NO. N/A 10 Acres Less 2.5 Acres off for Hiway

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
LOOSE SAND & GRAVEL		0	15	15
CEMENTED SAND		15	18	3
SANDY GRAVEL, ROCKS		18	42	24
HARD CEMENTED SAND		42	54	12
SANDY BRO CLAY		54	68	14
BRO CLAY		68	76	8
BOULDERS / SAND		76	102	26
SANDY BRO CLAY		102	125	23
SAND, COARSE GRAVEL	17	125	142	17
BRO SANDY CLAY		142	155	13
SAND, GRAVEL to 1"	15	155	170	15
BRO SANDY CLAY		155	185	30
SAND GRAVEL to 1"	9	185	194	9
BRO CLAY		194	200	6

RECEIVED
NOV 16 1979
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 9-23, 19 79
Date completed 10-20, 19 79

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3450	30 GPM	6'	4 HRS

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole ..... inches Total depth 200 feet
Casing record 202' 8 5/8
Weight per foot 16.94 Thickness 1.88

Diameter	From	To
12" inches	0 feet	50 feet
10½ inches	50 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐, Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 200' feet

Perforations:
Type perforation TORCH CUT
Size perforation ¼ X 4
From 125' feet to 200' feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 123' Feet below land surface
Flow ..... G.P.M.
Water temperature Warm ° F. Quality Clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name David C. Boyd
Address P.O. Box 86 Lathrop Wells, NV 89020
Nevada contractor's license number 14214
Nevada driller's license number 1127
Signed David C. Boyd
Date 11-13-79

USE ADDITIONAL SHEETS IF NECESSARY

5471