WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 52331
Permit No.
Basin

1. OWNER FRED L. WHITE ADDRESS LATHROP WELLS NV 89020

2. LOCATION N.W. ¼ S.E ¼ Sec. 5 T. 16S N/S R. 49 E. MDBM NYE County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface SAND & GRAVEL		0	15	15
SANDY GRAVEL		15	20	5
SAND- FINE		20	25	5
SANDY CLAY		25	30	5
SAND GRAVEL TO 1½ IN.		30	35	5
SANDY CLAY BROWN		35	55	20
SAND, GRAVEL TO 1"		55	75	20
SANDY CLAY BRN.		75	85	10
SAND, STREAKS OF CLAY		85	120	35
SAND FINE TO COURSE		120	125	5
BRO. SANDY CLAY	156	125	156	31
FINE SAND, GRAVEL		156	170	14
COURSE SAND & GRAVEL		170	181	11
SANDY BRO CLAY		181	189	8
COURSE SAND		189	197	8
SANDY CLAY		197	208	11
COURSE SAND & GRAVEL		208	232	24
SANDY SM. GRAVEL		232	241	9
CLAY BROWN		241	251	10

Date started Aug. 15, 19 8
Date completed Oct. 9, 19 8

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
NOV 1 1978
Div. of Water Resources
Branch Office — Las Vegas, NV

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12" inches Total depth 250 feet
Casing record 251 ft
Weight per foot ..... Thickness 3/16

Diameter	From	To
12 inches	0 feet	50 feet
10 3/4 inches	50 feet	250 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 ft feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 250 feet

Perforations:
Type perforation TORCH
Size perforation 1/4 X 4 in
From 150 feet to 250 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 156 Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name FRED L. WHITE
Address LATHROP WELLS NV.
Nevada contractor's license number 911
Nevada driller's license number 911
Signed Don D. Trenary
Date Oct 12 1978

USE ADDITIONAL SHEETS IF NECESSARY

5471