WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

M. R.

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 5243
Permit No.
Basin 220

1. OWNER Earnest L. Mathis ADDRESS Overton, Nevada
SW Corner of the SW 1/4 of the NW 1/4 of Sec 12 T16S R67E

2. LOCATION SW ¼ NW ¼ Sec. 12 T. 16 N/S R. 67 E. Clark County
PERMIT NO.

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [ ] Irrigation [X] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surf Soil		0	15	
Sand & Clay		15	41	
Clay		41	67	
Rock & Clay		67	83	
Gravel & Sand Rock		83	96	
Clay & Rock		96	104	

RECEIVED
MAY 23 1977
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 4-3, 1977
Date completed 4-30, 1977

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 35 Draw down 48 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 104 feet
Casing record Steel
Weight per foot Thickness 105

Diameter	From	To
6 inches	0 feet	104 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [ ] No [ ] Type Pump
Depth of seal feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 0 feet to 104 feet

Perforations:
Type perforation Slotted 3/16 x 6
Size perforation
From 60 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 18 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name B & B Drilling Co
Address Beaver Utah
Nevada contractor's license number 7381
Nevada driller's license number 818
Signed Ronald Brabham
Date May 21-77

USE ADDITIONAL SHEETS IF NECESSARY

5471