WHITE–DIVISION OF WATER RESOURCES
CANARY–CLIENT'S COPY
PINK–WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No 52492
Permit No.
Basin 212

NOTICE OF INTENT NO. 17538

1. OWNER UNLV
MAILING ADDRESS 4505 MARYLAND PKWY
LAS VEGAS NV

ADDRESS AT WELL LOCATION Harmon Ave + Gym Drive

2. LOCATION NE ¼ SE ¼ Sec 22 T 21 N/S R 61 E Clark County
PERMIT NO. MO-2706 (Issued by Water Resources) 162-22-701-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED: ☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE: ☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☒ Stock

5. WELL TYPE: ☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	1/4	1/4
Sandy Clay		1/4	2	1 3/4
Silty Clay		2	4	2
Sandy Clay		4	5	1
Clayey sand		5	7	2
Sandy clay w/gravel		7	8	1
Caliche	9 1/2	8	10 1/2	2 1/2
Clayey sand w/gravel		10 1/2	13	2 1/2
Caliche		13	14 1/2	1 1/2
Clay w/gravel + sand		14 1/2	24	9 1/2
clay sl. gravel		24	24 1/2	1/2
caliche / lean clay		24 1/2	30	5 1/2

Date started March 26, 1996
Date completed March 26, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	30 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.218"	0	30

Perforations:
Type perforation Factory Slot
Size perforation 0.02"
From 5 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0'-1' cement 1'-3' bentonite
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 3 feet to 30 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DON WILSON
Address 731 PILOT RD. STE H (Contractor)
LAS VEGAS, NV 89119 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589
Signed (By driller performing actual drilling on site or contractor)
Date 6-21-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627