

OFFICE USE ONLY
 Log No. 525516
 Permit No. _____
 Basin. 162


PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 6633

1. OWNER Paul Christopher ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____

2. LOCATION SW 1/4 NW 1/4 Sec. 15 T. 19-S N/S R. 53 E Nye County _____
 PERMIT NO. APN 29-231-02 10 Unit 1 Block 9 Country Place II
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Soft Sandy Clay		4	16	12
Clay/Small Gravel		16	38	22
Grey Clay/Lg. Gravel		38	62	24
Soft Brown Clay		62	114	52
Clay / Gravel	x	114	124	10
Hard Formation(Soft Shale)		124	130	6
Soft Brown Clay	x	130	178	48
Brown Clay/sm Gravel		178	200	22

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 Inches 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	18lbs.	.188	0	200

Perforations:
 Type perforation Torch Cut
 Size perforation 1/2 in width 8 in long
 From 160 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 107 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Charles Nyberg Contractor
 Address HCR 77 BOX 36525 Pahrump NV 89041 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 7484
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
 Signed Charles Nyberg
 By driller performing actual drilling on site or contractor
 Date June 24, 1996

Date started June 13 1996
 Date completed June 16 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	1/4