WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 52593
Permit No.
Basin 162

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8791

1. OWNER Lucky Cuse
MAILING ADDRESS
ADDRESS AT WELL LOCATION Piltz

2. LOCATION NE ¼ NE ¼ Sec. 8 T. 20s N/S R. 53 E. NYE County
PERMIT NO. N/A (Issued by Water Resources) Parcel No. Lot 27 Unit c cal vegas Ranchoes (Subdivision Name)

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay		0'	18'	18'
calichie		18'	21'	3'
clay		21'	32'	11'
calichie		32'	34'	2'
clay		34'	36'	2'
calichie		36'	37'	1'
clay		37'	49'	12'
calichie		49'	52'	3'
clay		52'	56'	4'
calichie	W.B	56'	58'	2'
clay		58'	62'	4'
calichie	W.B	62'	64'	2'
clay		64'	78'	14'
calichie	W.B	78'	80'	2'
clay		80'	82'	2'
calichie	W.B	82'	85'	3'
clay		85'	95'	10'
calichie	W.B	95'	97'	2'
clay		97'	102'	5'
calichie	W.B	102'	105'	3'
clay		105'	114'	9'
calichie	W.B	114'	116'	2'
clay		116'	125'	9'
calichie	W.B	125'	127'	2'
clay		127'	132'	5'
calichie	W.B	132'	135'	3'
clay		135'	140'	5'

Date started 10-30, 19 90
Date completed 11-3, 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
NOV 21 1990
Div. of Water Resources
Branch Office - Las Vegas, NV

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 140' feet
inches
inches
Casing record 140' x 8 5/8"
Weight per foot 16.94 Thickness .188

Diameter	From	To
8 5/8" inches	0 feet	140' feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type concrete
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 140 feet to 50 feet

Perforations:
Type perforation factory sawcut
Size perforation 1/8" x 3"
From 140 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 45 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING (Contractor)
Address HCR 65 box 80358 Pahrump, Nv 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada contractor's driller's number issued by the Division of Water Resources 1426
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11-19-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627