


WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 52597
Permit No.
Basin 162



1. OWNER Clayton Ellipson ADDRESS Palhramp
Chaparral Ranchos -
2. LOCATION S.E. 1/4 S.W. 1/4 Sec. 8 T. 20 N/S R. 53 E Wye County
PERMIT NO. Domestic

3. TYPE OF WORK: New Well, Recondition, Deepen, Other
4. PROPOSED USE: Domestic, Irrigation, Test, Municipal, Industrial, Stock
5. TYPE WELL: Cable, Rotary, Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP Soil		0	6	6
Caliche		6	18	12
Clay	✓	18	48	30
Caliche		48	56	08
Clay		56	89	33
Hard Caliche	2	89	90	01
Strip of Caliche	✓	90	99	09
Clay		99	120	21

8. WELL CONSTRUCTION
Diameter hole 12-3/4 inches Total depth 120 feet
Casing record 8 5/8" O.D.
Weight per foot 12.50 Thickness 10 gage
Diameter 8 5/8 inches From 7.1 feet To 120 feet
Surface seal: Yes No Type _____
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from 50 feet to 120 feet
Perforations:
Type perforation Teach Cut
Size perforation 18 x 6 3 Rounds
From 60 feet to 120 feet

RECEIVED

AUG 2, 1972

DIV. OF WATER RESOURCES
BRANCH OFFICE
LAS VEGAS, NEVADA

9. WATER LEVEL
Static water level 29 Feet below land surface
Flow _____ G.P.M.
Water temperature _____ ° F. Quality good

Date started 5/19/72
Date completed 6/21/72

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Floyd Pump Co.
Address P.O. Box 157 Palhramp
Nevada contractor's license number 7479-
Nevada driller's license number 476
Signed Kenny S. Floyd
Date 6/26/72

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours