WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 52629
Permit No.
Basin 212

NOTICE OF INTENT NO. 17534

1. OWNER Clark County Dept. of Aviation
MAILING ADDRESS P.O. Box 11005
Las Vegas, NV 89111

ADDRESS AT WELL LOCATION McCarran International Airport

2. LOCATION NE ¼ NW ¼ Sec. 34 T 21 ~~N~~/S R. 61 E. Clark County
PERMIT NO. MD-2687 (Issued by Water Resources) 162-34-201-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE MW-1
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ~~☐ Other~~ AUGER NGA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0	0.5'	0.5'
SILTY SAND		0.5'	3'	2.5'
GRAVELLY SAND		3'	6'	3'
CLAYEY SAND		6'	7'	1'
SAND		7'	9'	2'
CALICHE		9'	12'	3'
SILT		12'	13'	1'
SILTY CLAY		13'	19'	6'
CALICHE		19'	28'	9'
SANDY SILT		28'	33'	5'
CLAYEY SILT		33'	37.5'	4.5'
CLAY		37.5'	40'	2.5'

Date started March 7, 1996
Date completed March 7, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	40 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	40

Perforations:
Type perforation Factory Slot
Size perforation 0.020"
From 15 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0'-7' concrete, 7'-13' Bentonite
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 13 feet to 40 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DON WILSON (Contractor)
Address 731 PILOT RD., STE H (Contractor)
LAS VEGAS, NV 89119
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1589
Signed (By driller performing actual drilling on site or contractor)
Date 6-25-96

CNHD JUL 2 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627