WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 52654 in Book
Permit No.
Basin 162

PERMIT # 0924

1. OWNER HAROLD A. LUTZ ADDRESS PAHRUMP, NEVADA 89041

2. LOCATION NE ¼ NE ¼ Sec. 8 T. 20-S N/S R. 53 E. NYE County
PERMIT NO.

3. TYPE OF WORK
New Well XX Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic XX Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable XX Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SURFACE		0	4	4
BROWN CLAY		4	46	42
TOUGH CLAY		46	54	8
BROWN CLAY	X	54	140	86

RECEIVED
DEC 6 1982
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started OCTOBER 28, 19 82
Date completed OCTOBER 29, 19 82

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 3 feet 1/4 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8" inches Total depth 140 feet
Casing record 8" CASING
Weight per foot 15# Thickness .56

Diameter	From	To
8" inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CONCRETE
Depth of seal 50' feet
Gravel packed: Yes XX No ☐
Gravel packed from 50 feet to 140 feet

Perforations:
Type perforation TORCH CUT
Size perforation 3/8" W X 8" L
From 80 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 32 Feet below land surface 31
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CHARLES NYBERG
Address STAR ROUTE BOX 5231 PAHRUMP, NEV. 89041
Nevada contractor's license number 7484
Nevada driller's license number 725
Signed Charles Nyberg
Date 1/12/82

USE ADDITIONAL SHEETS IF NECESSARY

O-627