WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 52716
Permit No.
Basin 212

NOTICE OF INTENT NO. 10932

1. OWNER Las Vegas Paving
MAILING ADDRESS 4920 S. Decatur
Las Vegas NV 89103

ADDRESS AT WELL LOCATION Harmon & Harmony

2. LOCATION ¼ ¼ Sec. 24 T. 21 N/S R. 61 E County
PERMIT NO. DW-1024 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other Temp

4. PROPOSED USE Dewater
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other Bucket

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Fill Sand | | 0 | 2 | 2 |
| Silty Clay | | 2 | 16 | 14 |
| Sand Clay | | 16 | 26 | 10 |
| Caliche | | 26 | 27 | 1 |
| Silty Clay | | 27 | 35 | 8 |
| Clay | | 35 | 40 | 4 |

RECEIVED
MAR 20 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 3-3, 1995
Date completed 3-3, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 24" | 0 | 40 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8" | | Sch 40 | 0 | 40 |
| | | | | |

Perforations:
Type perforation Saw Cut
Size perforation .030
From 20 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☑ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 0 feet to 40 feet

9. WATER LEVEL
Static water level 16 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Griffin Contract Dewatering Contractor
Address 536 E. Maitland Contractor
Ontario CA 91761
Nevada contractor's license number issued by the State Contractor's Board 0031246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller N1968T
Signed By driller performing actual drilling on site or contractor
Date 3-4-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627