WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 52739
Permit No.
Basin 212

NOTICE OF INTENT NO. 15145

1. OWNER National Groundwater Assoc.
MAILING ADDRESS 2600 Groundwater Way Columbus, Ohio 43129
ADDRESS AT WELL LOCATION Vacant Lot, Riviera Blvd and Paradise, Las Vegas

2. LOCATION NW ¼ SE ¼ Sec. 9 T. 21 N/S R. 61 E/W Clark County
PERMIT NO. MO-2696 (Issued by Water Resources) | Parcel No. #2 | Subdivision Name Sheraton ITT Gaming Div

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Silt		0	4	4'
Caliche		4	5	1'
Sandy Silt		5	10	5'
Caliche		10	11	1'
Sandy Silt	12	11	20	9'
Sand-Clayey Silt		20	40	20'
I.D.				
Workshop #7B				

Date started May 12, 1996
Date completed May 12, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Not Tested		

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	40 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	PVC	Sch 40	0	40

Perforations:
Type perforation Machine Slotted
Size perforation .02
From 10 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 8
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout ☑ Bentonite Grout
Gravel Packed: ☒ Yes ☐ No
From 8 feet to 40 feet

9. WATER LEVEL
Static water level 1½ feet below land surface
Artesian flow Ø G.P.M. P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gregg Drilling and Testing Inc. (Contractor)
Address 2975 Cerritos Ave (Contractor)
Signal Hill, CA. 90806
Nevada contractor's license number issued by the State Contractor's Board 0038113
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2018-M1
Signed Donald T. Mayer (By driller performing actual drilling on site or contractor)
Date June 10, 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627