WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

in Book

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 52347
Permit No.
Basin 235

1. OWNER KEITH STRICKLAND ADDRESS Star Rt 15 Box 612 Lathrop Wells, NV 89020

2. LOCATION SE ¼ SW ¼ Sec. 35 T. 16S N/S R. 49 E. MDBM Nye County
PERMIT NO. S½ of Govt Lot 7

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SANDY SOIL		0	4	4
SANDY CLAY		4	27	23
HARD CEMENTED SAND		27	31	4
SANDY CLAY		31	38	4
HARD CEMENTED SAND		38	42	4
BRN. SANDY CLAY		42	48	6
HARD CEMENTED SAND		48	55	7
SANDY CLAY BRN.		55	59	4
HARD CEMENTED SAND		59	63	4
BRN. SANDY CLAY		63	80	17
" " "		80	97	17
BRN. CLAY SOME SAND		97	100	3
FINE SAND & GRAVEL	8	100	108	8
BRN. SANDY CLAY		108	124	6
SAND COURSE GRAVEL	6	124	130	6
HARD CEMENTED LIME		130	134	4
SAND, GRAVEL TO 1"		134	150	6
SANDY CLAY BRN.		150	171	21
SAND & GRAVEL	9'	171	180	9
BRN. CLAY		180	183	3
SAND & GRAVEL		183	189	5
BRN. CLAY		189	193	4

Date started June 2, 1979
Date completed July 10, 1979

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	NO TEST		

RECEIVED
AUG 20 1979
Div. of Water Resources
Branch Office—Las Vegas, Nev.

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 193 feet
Casing record 193' of 8"
Weight per foot 16.94 Thickness .188

Diameter	From	To
12 inches	100 feet	100 feet
9 1/2 inches	100 feet	193 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal ..... feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 189 feet

Perforations:
Type perforation TORCH CUT
Size perforation 4X 1/4"
From 93' feet to 190' feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 92 Feet below land surface 92
Flow ..... G.P.M.
Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name DON. G TRENARY
Address LATHROP WELLS NV.
Nevada contractor's license number C-D Co 14214 ~~97~~ DeBoyd
Nevada driller's license number 971
Signed Don G. Trenary
Date Aug 1 1979

USE ADDITIONAL SHEETS IF NECESSARY

5471