WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 52922
Permit No. 56392
Basin 212

NOTICE OF INTENT NO. 15783

1. OWNER Ron Ayers - Terry McNaulty
MAILING ADDRESS P.O. Box 81260
Las Vegas NV. 89180

ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ SE ¼ Sec. 11 T. 19 N/S R. 60 E. CLARK County
PERMIT NO. 56392 Issued by Water Resources
12511 302002 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel & Clay's		0	20	
Brown Clay		20	30	
Gravel		30	65	
Brown Clay		65	75	
Gravel		75	170	
Sand Gravels	S Gal	170	185	
Clay		185	245	
Gravel	30	245	275	
Clay		275	290	
Sand Gravel	95	290	305	
Clay		305	400	
Sand Gravels	40	400	450	
Clay's		450	470	
Sand Gravels		470	500	

Date started 6-9, 1996
Date completed 6-19, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 480 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 ¼ Inches		0 Feet	500 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	17	188	0	480

Perforations:
Type perforation Torch
Size perforation 48
From 440 feet to 480 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 Feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 480 feet

9. WATER LEVEL
Static water level 172 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Redding Drilling Contractor
Address 8170 S Haven Contractor
Lv NV 89123
Nevada contractor's license number issued by the State Contractor's Board 38155
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1798
Signed [signature] By driller performing actual drilling on site or contractor
Date 6-21-96

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627