

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 8394

1. OWNER Donald F. Derby ADDRESS AT WELL LOCATION W To Rae
 MAILING ADDRESS 300 E Tropicana & Industrial
LV NV 89109 3375 W 30 RAE AVE
 2. LOCATION SE 1/4 NW 1/4 Sec. 29 T. 22 N/S R. 61 E Clark County
 PERMIT NO. 177-29-203-004 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Gravel's Boulders		0	75	
Red Sand Stone		75	100	
Sand Gravel Boulders		100	110	
Same		110	155	
Red Sand Stone	5' Grk	155	215	
Sand Gravel's Boulder		215	255	
Red Sand Stone		255	265	
Sand Gravel Boulders		265	320	
Red Sand Stone		320	330	
Sand Gravel's bowl		330	355	

8. WELL CONSTRUCTION
 Depth Drilled 355 Feet Depth Cased 355 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 355 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>		<u>188</u>	<u>0</u>	<u>300</u>
<u>6 5/8</u>		<u>188</u>	<u>280</u>	<u>355</u>

Perforations:
 Type perforation Torch
 Size perforation 18 inch
 From 300 feet to 355 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 355 feet

9. WATER LEVEL
 Static water level 165 feet below land surface
 Artesian flow NO G.P.M. _____ P.S.I. _____
 Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Redding Drilling Contractor
 Address 8170 Haven Contractor
LV NV 89123
 Nevada contractor's license number 38155
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1798
 Division of Water Resources, the on-site driller
 Signed Donald F. Derby
 By driller performing actual drilling on site or contractor
 Date 4-25-96

Date started 4-10 1996
 Date completed 4-24 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>33</u>		

