

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17415

1. OWNER KENT RUDD ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_  
TENEYA & RICHMAR  
 2. LOCATION SE 1/4 SW 1/4 Sec. 22 T. 22 N/S R. 60 E. CLARK County \_\_\_\_\_  
 PERMIT NO. 176-22-401-002 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_


6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>SANDY CLAY, GRAVEL + ROCKS.</u>		<u>0</u>	<u>30</u>	<u>30</u>
<u>CMT. GRAVEL.</u>		<u>30</u>	<u>50</u>	<u>20</u>
<u>SANDSTONE</u>		<u>50</u>	<u>100</u>	<u>50</u>
<u>CMT GRAVEL w/ STRKS. LIMESTONE.</u>		<u>100</u>	<u>350</u>	<u>250</u>
<u>CMT GRAVEL w/ STRKS SANDSTONE.</u>	<u>500</u>	<u>350</u>	<u>600</u>	<u>250</u>

8. WELL CONSTRUCTION  
 Depth Drilled 600 Feet Depth Cased 600 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 9 7/8 Inches To 0 Feet 600 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5 5/8</u>	<u>10.9</u>	<u>.188</u>	<u>+1</u>	<u>600</u>

Perforations:  
 Type perforation FACTORY SAW.  
 Size perforation 1 7/8 x 2 1/2  
 From 540 feet to 580 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 600 feet



Date started 7-11, 1996  
 Date completed 7-13, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level 475 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name DESERT DRILLING Contractor  
 Address 6475 GARY AVE  
LAS VEGAS, NV. 89139  
 Nevada contractor's license number issued by the State Contractor's Board: 34274  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1594  
 Signed Timothy Couch  
 By driller performing actual drilling on site or contractor  
 Date 7-15-96

